



Certificate No:  
**AOSS0000KYF**

# APPROVAL OF SERVICE SUPPLIERS

This is to certify that

**Azsafety Production LLC**

**Baku, Azerbaijan**

is granted acceptance for

**Inspection and maintenance of fire extinguishing equipment and systems. Inspections and maintenance of self-contained breathing apparatus. In accordance with Class Programmes DNV-CP-0484 and DNV-CP-0624, and IACS UR Z17 Annex 1[7].**

This service supplier certificate will be accepted for use with all rule sets published by DNV.  
**See the following page(s) for details regarding application.**

This Certificate is valid from **2023-09-27** to (inclusive) **2026-09-26**.

This Certificate is issued on **2023-09-27**.

for **DNV**

.....  
**Huseynov, Rasul**  
**Surveyor**

This Certificate may be withdrawn if:

1. The service provided has been improperly carried out or the results improperly reported.
2. The surveyor has found any deficiencies in the accepted operating systems of the service supplier.
3. The firm has failed to inform of any major changes having effect on the quality of the service rendered.
4. The conditions listed in the certificate are changed and/or are not fulfilled.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



## Application:

Service Supplier: "Azsafety Produccion" LLC

Service Area: Inspection and Maintenance of Fire Extinguishing Equipment and Systems in accordance with Class Programme DNV-CP-0484 and DNV-CP-0624, and IACS UR Z17 Annex 1[7].

Approved activities for Firefighting systems:

- Portable and Mobile Fire Extinguishers
- Self-contained Breathing Apparatus and EEBD
- CO2 Fire Extinguishing systems (High and low pressure systems)
- Pressure Water Spraying Systems (Sprinkler and Deluge) including Water Mist Systems.
- Halon and other gaseous Fire Extinguishing systems
- Hydrostatic testing of Pressure Vessels
- Fixed Fire Extinguishing systems for Deep Fat Cooking.
- Level check of CO2 and other Gas cylinders.

## Remarks:

APPROVAL CONDITION:

The conditions to which the enclosed certificate based are:

1. Requirement stated in DNV Class Programme DNV-CP-0484 and DNV-CP-0624, and IACS UR Z17 Annex 1[7].
2. Initial audit performed by DNV Istanbul ref. checklist AOSS 611 dated 2023-09-22
3. Information of alteration to the Certified Service Operation System:

In case any alteration to the certified service operation system of the firm is made, such alteration shall be reported to DNV, immediately.

Intermediate/Renewal Audit:

- a. Renewal of the certificate shall be made at intervals not exceeding three (3) years by verification through audits that approved conditions are being maintained.
- b. Intermediate audits may be required by DNV as found necessary.
- c. At least 3 months before the period of validity expires, the supplier shall apply to DNV for renewal of the Certificate of Approval.

CANCELLATION OF APPROVAL:

Approval may be cancelled in the following cases:

1. Where the measurements were improperly carried out or the results are improperly reported.
2. Where a surveyor finds deficiencies in the approved service operating system of the firm and appropriate corrective action is not taken.
3. Where the firm fails to inform of any alteration as stated in item 3 of approval conditions.
4. Where willful acts or omissions are ascertained.
5. When new rule requirements make this necessary.

It is generally not required to have the name of approved supervisors and technicians listed or identified on the certificate. It is obligation of the company to follow their approved training programme and assign the tasks to the qualified personnel as required. The supplier shall maintain and update the list of supervisors and technicians based on the requirements. Any changes to the list shall be clarified with DNV. DNV reserves the right to require a new evaluation of the company based on the changes on the list.

Approval is valid for the services listed above only.